



D-SITE TEST CELL  
AUTOCLAVE VESSEL

- NOTE: UNLESS OTHERWISE SPECIFIED
1. ALL CABLE NUMBERS PREFIXED BY S144005.
  2. ALL HEATER/STRIPS ARE CHROMALOX 2000W P/N NS-3802-142527.
  3. \* DENOTES 200°C INSULATED WIRE, TYPE SRML.
  4. GROUND WIRE SHALL BE TERMINATED ON HEATER SUPPORT STUD.
  5. FOR EQUIPMENT LOCATION AND RACEWAY , SEE DWG. SE144E020, SE144E021 & SD144E022.

COMPUTER GENERATED DRAWING - MANUAL CHANGES NOT PERMITTED	CADD FILE NUMBER SB144E005.DWG								8				4				DIV	ELECTRICAL	APPROVED		PLASMA PHYSICS LABORATORY PRINCETON UNIVERSITY		NCSX SB144E005 SH 1
	7				3				ENG	F. JONES	DATE		2/03	NATIONAL COMPACT STELLARATOR EXPERIMENT MODULAR COILS									
	6				2				DR	RVK	CH	JJN	TOOLING AND WINDING										
	5				1				DATE	2-07-03	CH	JJN	SUPV	JS	AUTOCLAVE 2000W PRIMARY HTR 7-12								
	REV	DATE	BY	APPROVED	REV	DATE	BY	APPROVED															