


FROM
PLP-500
CKT-8, 45A
3 ϕ , 480V AC 60Hz
6000-B-52213-PL
LOCATED ON CART 1

CONTINUED FROM
DWG. SB144E011



D-SITE TEST CELL
AUTOCLAVE CONTROL PANEL
CART 2

COMBINATION MOTOR
CONTROLLER
480V AC, 3 ϕ
FLA = 29
SIZE 2

- NOTE: UNLESS OTHERWISE SPECIFIED
1. ALL CABLE NUMBERS PREFIXED BY S144010.
 2. FOR EQUIPMENT LOCATION, SEE DWG SE144E020.
 3. FOR ADDITIONAL WIRING, SEE DWG SD144E019.

COMPUTER GENERATED
DRAWING - MANUAL CHANGES
NOT PERMITTED

CADD FILE
NUMBER
SB144E010.DWG

8					4				
7					3				
6					2				
5					1				
REV	DATE	BY	APPROVED	REV	DATE	BY	APPROVED		

DIV ELECTRICAL
ENG F.JONES
DR RVK CH JUN
DATE 2-10-03

APPROVED
F. JONES
DATE 2/03
CH JUN SUPV JS

PLASMA PHYSICS LABORATORY
PRINCETON UNIVERSITY
NATIONAL COMPACT STELLARATOR EXPERIMENT
MODULAR COILS
TOOLING AND WINDING
AUTOCLAVE CRCLT HTR CTRL MS-4-ACLV

NCSX
SB144E010
SH 1