

*NCSX*  
*Copper Conductor Keystoning Tests*

***NCSX***

Copper Cable Keystone Tests

By: Jim Chrzanowski

November 5, 2001

**NCSX**  
**Copper Conductor Keystoning Tests**

**SCOPE:** Perform tests on the proposed rectangular compacted copper cable to determine the amount of Keystoning which would result during winding of the Modular coils for NCSX. Two Keystone trials were performed winding the copper braid conductor in both directions. Trial #1 was performed winding the conductor with the narrow side against the mandrel. Trial #2 was performed winding the conductor with the wide side against the mandrel.


1. Measurements were taken with the copper cable conductor bare. (See Table 1)
2. One half-lapped layer of dry glass insulation was applied over the bare conductor. (1 inch wide x 0.007 inches thick)
3. Measurements were taken with insulation on conductor. (See Table 1)
4. The insulated conductor was hand wound onto a mandrel with a measured diameter of 3.181 inches.(8.08 cm).
5. Once wound, conductor measurements were taken. These steps were repeated for both trial sets.

**Table 1- Initial Conductor Measurements**

Location	Bare Side A	Insulated Side A	Bare Side B	Insulated Side B
1	0.631	0.653	0.519	0.541
2	0.637	0.655	0.520	0.542
3	0.640	0.660	0.525	0.553
4	0.640	0.660	0.529	0.548
5	0.640	0.664	0.525	0.547
6	0.640	0.660	0.534	0.554
7	0.640	0.665	0.539	0.558
8	0.642	0.668	0.538	0.556
9	0.633	0.660	0.537	0.557
10	0.635	0.660	0.535	0.557
11	0.635	0.650	0.535	0.556
12	0.635	0.665	0.530	0.548
Average	0.637	0.660	0.531	0.551


**Trial #1- Conductor**  
*Winding Direction*

**Trial #2- Conductor**  
*Winding Direction*



**NCSX**  
**Copper Conductor Keystoning Tests**

**Results of Keystone Tests**



**Table –2 Keystone Results- Trial #1**

Location	Insulated Side A	Insulated Side B	Insulated Side C	Insulated Side D
1	0.663	0.650	0.505	0.631
2	0.652	0.647	0.510	0.645
3	0.668	0.655	0.504	0.638
4	0.658	0.662	0.510	0.649
5	0.680	0.670	0.520	0.661
6	0.667	0.660	0.512	0.646
7	0.658	0.650	0.515	0.650
8	0.665	0.640	0.514	0.662
9	0.670	0.645	0.510	0.640
<b>Average</b>	<b>0.665</b>	<b>0.653</b>	<b>0.511</b>	<b>0.647</b>


**Table-3 Keystone Results- Trial #2**

Location	Insulated Side A	Insulated Side B	Insulated Side C	Insulated Side D
1	N/A	N/A	0.716	0.635
2	0.545	0.543	0.719	0.624
3	0.542	0.541	0.721	0.641
4	0.577	0.572	0.723	0.640
5	0.552	0.591	0.735	0.640
6	0.570	0.593	0.733	0.650
7	0.561	0.575	0.735	0.641
8	0.521	0.554	0.748	0.628
9	0.539	0.550	0.722	0.628
<b>Average</b>	<b>0.551</b>	<b>0.565</b>	<b>0.728</b>	<b>0.636</b>

*NCSX  
Copper Conductor Keystoning Tests*

**Summary of Results**



*Trial #1.....Conductor Measurements*



**Figure 1- Trial #1 “Conductor Removed from Mandrel”**

**NCSX**  
**Copper Conductor Keystoning Tests**

**Trial #2..... Conductor Measurements**



**Figure 2- Trial #2 “Conductor Removed from Mandrel”**

**Note:** Any discrepancies in measurements are a result of conductor not being entirely rectangular prior to start of Trial #1 and reuse of same copper cable conductor for Trial #2.