


NCSX MODULAR COIL COOLING
NCSX ENGINEERING MEETING
3 APRIL 2002
FRED DAHLGREN


NCSX LN2 Coil Cooling Analysis:

- Transient finite-difference code FCOOL 2.2.
- Use a “lumped Mass” to represent Mod. coil conductor.
- Use an equivalent heat transfer septum length for Mod.Coils.
- Use a 1/4” O.D. tube, 0.04” wall thickness for Mod. Coils.
- Use a 0.040” thick septum for Modular Coils..
- Use 77 deg.K LN2 inlet temp.
- Use 2 -4 psi pressure drop.
- Use NIST webbook parameters for LN2 coolant @250psia.
- Varied ∂P & HTL



PARAMETERS:

PRESSURE DROP: 10.00 P SI
 VELOCITY: 13.39 FT / SE C.
 FLOW RATE: 0.94 GPM
 MDOT: 0.11 LB S / SEC
 PATH LENGTH: 21.50 FT.
 REYNOLDS NO.: 83246.51
 h-film: 1.55 btu / ft -sec -deg. F
 CUR. DENSITY: 85034.02 amp / sq.in
 TIME INCR.: 0.03211 SEC
 ESW: 1.20 SEC.
 REP. RATE: 90.00 S EC.
 INLET TEMP.: 138.00 deg. R
 CMASS: 3.75 LBS
 HTL: 0.42000 FT.
 NODE INTERVAL: 0.43000 FT.



Thermal Analog - thermal resistance





$$\begin{aligned}
 R_1 &= \frac{L_{\text{HEAT-SINK}}}{K_{\text{HEAT-SINK}} \cdot A_{\text{HEAT-SINK}}} \\
 R_2 &= \frac{L_{\text{INSULATION}}}{K_{\text{INSULATION}} \cdot A_{\text{INSULATION}}} \\
 R_3 &= \frac{L_{\text{Cu COND.}}}{K_{\text{Cu COND.}} \cdot A_{\text{Cu COND.}}}
 \end{aligned}
 \left. \vphantom{\begin{aligned} R_1 \\ R_2 \\ R_3 \end{aligned}} \right\} \frac{\text{HTL}}{K_{\text{Cu}} \cdot A_{\text{COND.}}} = \sum R_i$$

$$A_{\text{COND.}} = A_{\text{Cu COND.}} \cdot \text{DL} \div \text{HTL}$$

$$\text{HTL} = \left(K_{\text{Cu}} \cdot A_{\text{Cu COND.}} \cdot \text{DL} \sum R_i \right)$$



$$\begin{aligned}
 \sum R_i &= 0.224 + 0.152 + 0.000257 \\
 &= 0.376
 \end{aligned}$$

$$\begin{aligned}
 \text{HTL} &= (558 \cdot 0.00196 \cdot 0.486 \cdot 0.376)^{1/2} \\
 &= 0.445 \text{ ft. (for } 0.080'' \text{ thk septum } = 0.345 \text{ ft.)}
 \end{aligned}$$



NCSX - M1-COIL 1/4dia. Cooled Both Sides -04/02/02


NCSX - M2-COIL 1/4 dia. Cooled Both Sides -04/02/02



NCSX - M3-COIL 1/4 dia. Cooled Both Sides -04/02/02

Wed Apr 3 09:15:41 2002


PLOTTED ON:



NCSX - PF-3 - 1.1sec. ESW - 10kA - 623ft.

Tue Apr 2 21:24:23 2002


PLOTTED ON:



NCSX - PF-5 - 2.5sec. ESW - 8.6kA - 528ft. (2 paths/coil)

Tue Apr 2 20:40:13 2002


PLOTTED ON:



NCSX - PF-4 1.6sec. ESW - 10kA - 606ft.(2 path/coil)

Tue Apr 2 21:39:34 2002

PLOTTED ON:



NCSX - PF-6 1.5sec. ESW - 16.8kA - 445ft.


NCSX COIL SYSTEMS - THERMO-HYDRAULIC DATA

	ESW	I (kA)	ΔT (peak-deg.K)	T max (deg.K)	ΔP(psi)	GPM/coil	GPM (total)
M1	1.2	24.0	36.1	1174	10	0.88	5.2
M2	1.2	24.0	36.2	1172	10	0.90	5.4
M3	1.2	24.0	36.4	1165	10	0.94	5.6
PF1	1.5	30.0	7.9	849	2	0.92	1.9
PF2	1.5	38.0	12.4	89.4	2	1.14	2.3
PF3	1.1	10.0	0.3	77.3	2	0.68	1.4
PF4	1.6	10.0	0.7	77.7	2	0.68 ^l	2.8
PF5	2.5	8.6	0.7	77.7	2	0.75 ^l	3.0
PF6	1.5	16.8	2.2	79.2	2	0.82	1.7
TF1	3.2	18.0	5.6	82.4	2	0.95	5.7
TF2	3.2	18.0	5.6	82.4	2	0.95	5.7
TF3	3.2	18.0	5.6	82.4	2	0.95	5.7
							46.4

PLOTTED ON:

Wed Apr 3 11:06:52 2002

DEG. K



NCSX - M-1 COIL Re-Run with 2psi drop