






# NCSX PF Coil PDR

NCSX



Michael Kalish  
Joseph Rushinski  
Len Myatt  
Fred Dahlgren

# Outline

NCSX

---

- *Requirements*
- *Design*
- *Analysis and Testing*
- *Procurement Plan, Cost and Schedule*

# Requirements

NCSX

- The PF coils will be designed to meet the requirements of all the reference scenarios. [Ref. GRD Section 3.2.1.5.3.3.2]
  - 1.7 T Ohmic Scenario
  - 1.7 T High Beta Scenario
  - 2 T High Beta Scenario
  - 1.2 T Long Pulse
  - 320 kA Ohmic Scenario
- Electrical
  - Voltage standoff to resist maximum operating voltage of 4KV for PF4
  - Voltage standoff to resist maximum operating voltage of 2KV for PF5 and PF6
  - For PF4 & PF6 Upper and Lower Coils are in series
  - For PF5 Upper and Lower Coils are in Parallel
  - Maintenance Test, Manufacturing Test, and Design Standoff formulas defined

# Requirements

NCSX


---

## Tolerance / Location

- Global requirement is that toroidal flux in island regions shall not exceed 10%
- In plane installed perturbations less than +/- 3mm
- Out of plane installed perturbations less than +/- 3mm
- Leads and Transitions must have a less than 1% effect on toroidal flux in island regions
- Cooling
  - Pre-Pulse Temp of 80K
  - Pulse repetition rate recovery shall not exceed 15 minutes
- Design Life
  - 13,000 cycles per year
  - 130,000 cycles per lifetime


# PF Coil Layout

NCSX



# PF Coil Layout

NCSX




PF4 Upper

PF5 Upper

PF6 Upper




PF6 Lower



# PF Coil Cross Section





NCSX

- PF Coils of conventional design
- Rectangular cross section
- Round Geometry



# PF Coils, Conductor

NCSX




- A single copper conductor size is used for all three different types of PF coils to simplify their manufacture and reduce costs.



# PF4 Geometry

NCSX





- Turns = 80
- Outer Diameter = 49 inches
- Cross Section = 10 x 7.5 inches
- Conductor Length = 861 ft



# PF5 Geometry

NCSX

- Turns = 24
- Outer Diameter = 179 inches
- Cross Section = 7.7 x 6.4 inches
- Conductor Length = 1100 ft





NCSX PF Coil PDR 12/14/07

# PF6 Geometry

NCSX





- Turns = 14
- Outer Diameter = 216 inches
- Cross Section = 7.3 x 2.0 inches
- Conductor Length = 786 ft



# Lead Blocks

NCSX

- Leads Locked together by G11 Blocks
- Forces on leads very low on the order of 10 lbs excluding exterior fields



# Winding Pack Insulation Design

NCSX


PF Turn Insulation				
1/2 Lap Layer Kapton	Kapton	0.002		7.8
	Adhesive	0.0015		
	Kapton	0.002		0
	Adhesive	0.0015		
	Glass	0.007		0.63
	Glass	0.007		0.63
	Glass	0.007		0.63
	Glass	0.007		0.63
	Glass	0.007		0.63
	Glass	0.007		0.63
		<b>0.049</b>	<b>Inches</b>	<b>11.58 KV</b>
Ground Wrap PF				
Twenty One 1/2 Lap Layer	Glass	0.009		0.81
x 21	Glass	0.009		0.81
		<b>0.375</b>	<b>Inches</b>	<b>33.8 KV</b>

Kapton Tape applied directly to conductor to enhance turn to turn dielectric standoff and allow for decoupling of insulation from conductor during cool down.



- Generous 3/8" of ground wrap applied to provide "bullet proof" protection to prevent unforeseen potential damage

3/8" of Ground Wrap Insulation



# Turn To Turn Voltage Standoff Requirement

NCSX

- Substantial Margins in Turn to Turn Dielectric Standoff
- Design for 23KV
- Coils nominally see 1KV or less Turn to Turn
- Upper and Lower PF5 not in series raises Turn to Turn standoff requirement

		PF4 Upper &Lower	PF5 Upper	PF5 Lower	PF6 Upper &Lower
<b>Operating Voltage (KV)</b>	per coil for coils in series	2.00	2.00	2.00	2.00
<b># Of Dielectric Boundaries</b>		4.00	2.00	2.00	1.00
<b>Divide Total Voltage By:</b>	note: = #coils x #Boundaries for all upper and lower coils in series Except for PF5	8.00	2.00	2.00	2.00
<b>Turn to Turn (KV)</b>		0.25	1.00	1.00	1.00
<b>Maintenance Field Test Voltage (KV)</b>	(Operating Volatage x 2) + 1	0.63	2.50	2.50	2.50
<b>Manufacturing Test Voltage (KV)</b>	Maintenance Test Voltage x 1.5	0.94	3.75	3.75	3.75
<b>Design Volatge Standoff (KV)</b>	Manufacturing Test Voltage x 1.5	1.41	5.63	5.63	5.63
<b>Turn to Turn Glass Thickness</b>		0.084	0.084	0.084	0.084
<b>Coil Turn to Turn Long Term Break Down (90V/mil)</b>		23.16	23.16	23.16	23.16
<b>Coil Turn to Turn per CTD Test</b>		167	167	167	167
<b>Safety Factor (Break Down Voltage / Design Voltage Standoff Requirement)</b>		16.5	4.1	4.1	4.1

# Ground Plane Voltage Standoff Requirement

NCSX

- Voltage standoff to resist maximum operating voltage of 4KV
- Maintenance Test, Manufacturing Test, and Design Standoff formulas defined
- Design Voltage Standoff to ground is 45 KV for all three coils
- Ground Wrap dielectric standoff requirement meets system requirement

		PF4	PF5	PF6
Operating Voltage (KV)		2.00	4.00	2.00
Maintenance Field Test Voltage (KV)	(Operating Volatage x 2) + 1	5.00	9.00	5.00
Manufacturing Test Voltage (KV)	Maintenance Test Voltage x 1.5	7.50	13.50	7.50
Design Volatge Standoff (KV)	Manufacturing Test Voltage x 1.5	11.25	20.25	11.25
Turn to Turn Glass Thickness		0.084	0.084	0.084
Coil Turn to Turn Long Term Break Down (90V/mil+Kapton)		11.58	11.58	11.58
Ground Wrap Long Term Break Down		33.8	33.8	33.8
Standoff For Lead Stems KV		40.9	40.9	40.9
Standoff to Ground KV	Ground + Turn Insulation	45.3	45.3	45.3
Safety Factor Lead Stem (Lead Stem Standoff / Design Voltage Standoff Requirement)		3.6	2.0	3.6
Safety Factor to GND (Standoff to Ground / Design Voltage Standoff Requirement)		4.0	2.2	4.0

# Manufacturability - Manufacturing Tolerances

## NCSX


---

- Requirement = In plane and out of plane installed perturbations shall be less than +/- 3mm
- Coil specification will require +/- 1.5mm using half of the allowable installed tolerance budget
- D Shaped NCSX TF Coils have been manufactured to about a +/- 1.5mm tolerance in their free state but a guarantee of that over the larger diameters for the PF Coils is not guaranteed
- Coil as it is removed from the VPI mold will be within +/- 1mm but coil is likely to distort in it's free state
- Support structure must be capable of re-shaping coil as required
- Coils can be positioned during installation to average out of tolerance conditions



# Manufacturability- TF Brazed Joint

NCSX




- Example of a Typical Brazed Joint
- Sleeve is used with “Sil-Fos” Wafer and 1.5mm diameter ring. to ensure full coverage and no voids
- Induction brazing strongly recommended but may eliminate potential vendors

# Sensor Loop Placement

NCSX

- Sensor Loops will be applied to ID of coil as they are on TF Coils
- Applied under last layer of ground wrap insulation
- Twisted and brought out near leads
- Mounting provisions provided for splice box or strain relief



# Outline

NCSX

---

- *Requirements*
- *Design*
- *Analysis and Testing*
- *Procurement Plan, Cost and Schedule*

## Thermal / Hydraulic Analysis Requirements

NCSX


- Peak temperature and recovery time calculated for maximum required pulse (highest  $I^2T$  Operating Scenario) for each coil per the GRD
- Pulse Repetition not to exceed 15 minutes

	PF 4	PF5	PF6
Operating Scenario	320 kA Ohmic	1.7T High Beta	1.7T Ohmic
Equivalent Square Wave	.65 Seconds	.54 Seconds	.73 Seconds
Max Current	15155 Amps	7728 Amps	8195 Amps

# Thermal / Hydraulic Analysis Results

NCSX

- The pressure differential requirement is 60 psi for PF4 (same as the TF Coils).
- PF4 Peak temperature rise is 5 deg C
- PF4 base temperature increases by 3 deg C and then cycles 2 deg per each 15 minute pulse.
- PF5 and PF6 experience total temperature excursions of less than 2 deg C
- RMS Power is low enough that PF5 and PF6 could rely on convection cooling alone if necessary
- LN2 system Flow requirement is between 1 and 1.2 GPM per coil
- Total flow requirement for all six coils is less than 7 GPM



# Stress Analysis Inputs

## NCSX

- Time points analyzed for all scenarios
- Highest Loads not necessarily at maximum currents
- Coils analyzed with fixed and flexible supports
- Coils analyzed with and without thermal stress for worst case (highest force) operating conditions
- Note: Before FDR Analysis requires checking, some current inputs in the GRD have been changed since this analysis (I<sup>2</sup>T for PF4 +10% & I<sup>2</sup> for PF5 -30%)

Table 2.0-1 Magnetic Forces from Max Current Time Points

Time Point	PF4U	PF5U	PF6U
	[kN] Vertical/Radial	[kN] Vertical/Radial	[kN] Vertical/Radial
1.7 T Ohmic, t=0.0 s (PF6 I <sub>min</sub> )	-222/+725	+85/+22	-82/+53
2.0 T High-β, t=0.197 s (PF6 I <sub>max</sub> )	-87/+820	-11/+46	+10/+36
320 kA Ohmic, t=0.206 s (PF4 I <sub>min</sub> )	-201/+1984	-10/+82	+18/+19
1.7 T High-β, t=0.0 s (PF5 I <sub>max</sub> )	-46/+118	+68/+23	-72/+51
Gravity (from 3D ANSYS model)	-9.8/0	-14/0	-9.6/0

# Stress Analysis Thermal vs EM Hoop Deflections

NCSX

- Initial calculation demonstrates thermal deflections due to cool down predominate
- EM Hoop stress and deflection is insignificant
- Analysis indicates overall stresses are low if cool down is homogeneous





Table 2.0-2 Nominal Coil Hoop Stress and Radial Deflection


PF	Radial Force, $F_r$ [kN]	Coil Dimensions [m]			Ave. Hoop Stress, $\sigma_h$ $F_r/(2\pi drdz)$ [MPa]	Ave. Hoop Modulus <sup>1</sup> E [GPa]	Deflection [mm]	
		r	dr	dz			Magnetic $(\sigma_h/E)r$	Thermal $(\alpha\Delta T)r$
4	1984	0.522	0.1852	0.2473	7	93	0.04	1.5
5	82	2.223	0.0922	0.1574	1		0.02	6.2
6	53	2.720	0.0457	0.1798	1		0.03	7.6

# Stress Analysis Method

NCSX



- Model run with coils using smeared properties except for coil of interest which is modeled in detail





# Stress Analysis – Copper

NCSX


- Allowable copper stress  $S_m$  is 110 MPa
- Using a lower (softer) requirement than TF Coil ( $S_m=180$  MPa) could enhance manufacturability of PF Coils
- With coils and structure at the same temperature there remains a factor of safety of at least two
- Present structure design utilizes a clamped configuration so further analysis is recommended to identify the maximum allowable temperature differential between the structure and the coils

Run	PF	Radial Constraint	Temp Coil/Structure [K]	LC	Conductor Stress Intensity [MPa]
10	4	free	85/85	0	46.6
15		free	300/300	2	19.2
12		free	85/85	2	49.1
13		clamped	85/85	2	48.0
114		clamped	85/300	0	731
16	5	free	85/85	1	49.2
14		free	85/85	2	46.1
19		free	85/85	0	46.1
111		clamped	85/85	0	53.1
113		clamped	85/300	0	588
18	6	free	85/85	0	48.1
17		free	85/85	1	51.0
110		clamped	85/85	0	54.6
112		clamped	85/300	0	744

# Stress Analysis - Copper / Structure PDR Results

NCSX

- Analysis performed for Structure PDR confirms low stresses
- Note that stresses were higher in previous analysis which used a detailed winding pack model





Peak Tresca Stress In the PF coils is only 17.4 Mpa @ the PF5 & 6 support clamps

Results: LC1-1.7T Ohmic EM loads only

# Stress Analysis - Copper / Large Thermal Delta

NCSX



- PF6 Cu Stresses approach 620 MPa midway between coil supports with coil at 85K and coil supports at 300K
- PF4 and PF5 stresses as high
- Operational control of the cool down process will be critical

## Stress Analysis Insulation - In Plane & Compression

NCSX


- Stress allowable in plane limited to 165 MPA
- Stress allowable compression limited to 460 MPa
- Insulation Stress “In-Plane” and “Compression” has large margin
- Component of stress due to EM loads is very small

Run	PF	Radial Constraint	Temp Coil/Structure [K]	LC	In-Plane Compression/Tension [MPa]	Flat-Wise Compression [MPa]
10	4	free	85/85	0	-42.9/+9.6	-6.3
15		free	300/300	2	-0.6/+3.4	-3.0
12		free	85/85	2	-42.5/+10.1	-8.3
13		clamped	85/85	2	-41.4/+10.8	-8.3
114		clamped	85/300	0	-93.9/+81.3	-177
16	5	free	85/85	1	-40.9/+10.6	-7.4
14		free	85/85	2	-41.1/+10.4	-7.1
19		free	85/85	0	-40.7/+10.3	-7.1
111		clamped	85/85	0	-39.0/+12.9	-7.2
113		clamped	85/300	0	-49.5/+103	-81.8
18	6	free	85/85	0	-39.6/+10.2	-6.4
17		free	85/85	1	-40.7/+10.5	-6.6
110		clamped	85/85	0	-36.6/+13.0	-7.5
112		clamped	85/300	0	-110/+140	-99.5

# Stress Analysis Insulation Tensile

NCSX

- EM loads contribute insignificantly to the tensile insulation stress
- Analysis of local tensile loads indicates failure of the bond to the cooper conductor
- Testing pursued to determine if higher allowable tensile value could be used
- Testing indicates that tensile allowable is between “0” and 4.4 MPa



# Stress Analysis Insulation - Testing

NCSX

- Analysis showed risk of insulation cracking due to thermal stresses
- Original Plan to resolve thermal stress on winding pack issues
  - Remove Kapton to increase adhesion
  - Test to provide tensile stress allowables
  - Required greater than 10 MPa
- Results from CTD Testing Yielded Poor Results for Tensile strength / adhesion




Figure 5. Typical adhesion to metal surface failure.

# PDR Winding Pack Insulation Scheme

NCSX



- Original insulation scheme was re-evaluated and evolved to address thermal stress issue
- 1/2 Lap Layer of Kapton to provide primary dielectric strength
- System to allow loss of adhesion to conductor
- Releasing Kapton layer resolves thermal stress issue.
- Analysis verifies that coil stiffness is adequate after releasing insulation from conductors
- Prototype testing proved out insulation winding pack approach



# Prototype Bar Testing

NCSX


- Prototype bar underwent both thermal and stress cycling
- Proved durability of winding pack design
  - mechanical properties maintained after more than 2x stress at life
  - successful hipot tests
- Proved validity of FEA as measured by:
  - bench mark of mechanical properties to Bar model before and after cycling of prototype
- While the test bar was not identical to the PF geometry cyclical stresses tested were 5x greater than PF cyclical stresses
- Insulation scheme is identical to PF Coils





# Testing Prototype Bar, Thermal / Fatigue/ Electrical

NCSX



Test Equipment

Sealed Insulation box with test bar Inside





Bar Fitted with Probes for Electrical Testing after Cycling

Test Bar in the fixture with insulation box



# Testing TF Winding Pack, Thermal / Fatigue

NCSX



- **Beam Test Validates Analysis**

**Measured stiffness of beam bracketed by unbonded and bonded insulation analysis**

- **Beam Test Meets Mechanical Criteria for fatigue at > 2x stress at life**


**Stiffness of beam relatively unchanged after 140,000 cycles**

Max Load  $\approx$  8000 lbs.  
Total cycles  $\approx$  140,000

# Projected Fatigue Life for Conductor

NCSX

- Allowable number of cycles (N) based on 20 MPa alternating stress is greater than 100,000,000 (~infinite)
- Actual number of required cycles is 130,000



Fatigue Curve

# Analysis and Testing Summary

NCSX

---

- Analysis completed for operating scenarios / requirements as specified in the GRD
- Coils meet 15 minute rep rate with a maximum 5 deg C rise
- Conductor meets stress requirements with margin
- Insulation satisfies all relevant stress requirements with margin for in plane and compressive stress
- Cryogenic fatigue tests verify validity of Kapton to conductor insulation scheme at required fatigue life to satisfy tensile stress requirement
- Testing verifies analysis assumptions for composite beam properties
- Testing verifies dielectric standoff for turn to turn and turn to ground requirements

# Requirements Addressed

NCSX

---

- The PF coils will be designed to meet the requirements of all the reference scenarios. [Ref. GRD Section 3.2.1.5.3.3.2]
  - 1.7 T Ohmic Scenario
  - 1.7 T High Beta Scenario
  - 2 T High Beta Scenario
  - 1.2 T Long Pulse
  - 320 kA Ohmic Scenario

**STRESS ANALYSIS OK FOR ALL SCENERIOS**

- Electrical
  - Voltage standoff to resist maximum operating voltage of 4KV for PF4
  - Voltage standoff to resist maximum operating voltage of 2KV for PF5 and PF6
  - For PF4 & PF6 Upper and Lower Coils are in series
  - For PF5 Upper and Lower Coils are in Parallel
  - Maintenance Test, Manufacturing Test, and Design Standoff formulas defined

**DEMONSTRATED BY DESIGN AND TEST COILS WILL WITHSTAND THESE REQUIREMENTS**

# Requirements Addressed

NCSX

- **Tolerance / Location**

- Global requirement is that toroidal flux in island regions shall not exceed 10%
- In plane installed perturbations less than +/- 3mm
- Out of plane installed perturbations less than +/- 3mm
- Leads and Transitions must have a less than 1% effect on toroidal flux in island regions

**PROCUREMENT SPECIFICATION WILL ADDRESS TOLERANCES TF COILS BUILT TO SIMILAR TOLERANCES - MAY REQUIRE STRUCTURE TO COMPENSATE MUST CONFIRM LEAD AREA EFFECT ON FLUX**

- **Cooling**

- Pre-Pulse Temp of 80K
- Pulse repetition rate recovery shall not to exceed 15 minutes

**ANALYSIS CONFIRMS ACCEPTABLE TEMP. RISE AND REP RATE**

- **Design Life**

- 13,000 cycles per year
- 130,000 cycles per lifetime

**TESTING AND ANALYSIS CONFIRMS FATIGUE LIFE**

# Outline

NCSX

---

- *Requirements*
- *Design*
- *Analysis and Testing*
- ***Procurement Plan, Cost and Schedule***

# PF Coil Design Schedule

NCSX

Job: 1302 - PF Design -KALISH									
FY07 Rebaseline Exercise									
ECP53RBX02	FY07 Rebaseline exercise	22*	01MAY07A	31MAY07A	31MAY07A	100	4,529.98	4,529.98	
1302-200	Complete PF Coil SRD	6	03DEC07*	13DEC07	28AUG07	42 50	2,229.12	4,458.24	EA/EM =24hr ;
1302-205	Update PF Analysis	87*	06AUG07A	07DEC07	24OCT07	41 40	11,537.68	28,844.20	EA/EM =160hr ;
1302-210	Update PF Coil SDD	40	12SEP07A	29JAN08	21DEC07	41 50	2,208.21	4,416.41	EA/EM =24hr ;
1302-211	Complete PF4 PDR Model	97*	30JUL07A	14DEC07	26SEP07	44 90	12,954.87	14,394.30	EA/EM =00hr ; EA/DM =80 ;
1302-212	Complete PF5 PDR Model	91*	07AUG07A	14DEC07	24OCT07	44 90	12,985.26	14,428.07	EA/EM =00hr ; EA/DM =80 ;
1302-213	Complete PF6 PDR Model	91*	07AUG07A	14DEC07	21NOV07	44 90	12,985.26	14,428.07	EA/EM =00hr ; EA/DM =80 ;
1302-251	PDR Level Design Support	91*	07AUG07A	14DEC07	23NOV07	1,196 20	2,164.21	10,821.05	EA/EM =60hr ;
1302-220	Prepare for PDR	8	05DEC07	14DEC07	07DEC07	44	0.00	16,346.88	EA/EM =52hr ; EA/DM =36 ;
1302-225	3 PF Coils - PDR	1	R 14DEC07	14DEC07	11DEC07	44	0.00	2,972.16	EA/EM =16hr ;
1302-240	Disposition PDR Chits	6	17DEC07	02JAN08	17JAN08	44	0.00	4,458.24	CHRZANOWSKI =24hr ;
1302-214	Prepare,Review & Approve conductor spec	16	03JAN08	24JAN08	29JAN08	44	0.00	2,972.16	sv=16hr ;
1302-216	Prepare,Review & Approve coil spec	16	03JAN08	24JAN08	26FEB08	44	0.00	8,916.48	sv=48hr ;
1302-235	Detail Drawings PF4	25	14DEC07	28JAN08	17JAN08	42	0.00	14,860.80	PAUL =80 ;
1302-245	Detail Drawings PF5	25	14DEC07	28JAN08	14FEB08	42	0.00	14,860.80	PAUL =80 ;
1302-260	Detail Drawings PF6	25	14DEC07	28JAN08	13MAR08	42	0.00	14,860.80	PAUL =80 ;
1302-250	Analysis Support	25	14DEC07	28JAN08	13MAR08	42	0.00	13,003.20	KALISH =70hr ;
1302-217	Drawing Support	25	14DEC07	28JAN08	13MAR08	42	0.00	11,145.60	CHRZANOWSKI =60hr ; PAUL =00hr ;
1302-218	PF Stress Analysis with leads	20	17DEC07*	22JAN08	31JAN08	46	0.00	22,291.20	FAN =120hr ; PAUL =00hr ;
1302-265	Prepare for FDR	15	16JAN08*	05FEB08	20MAR08	36	0.00	19,319.04	CHRZANOWSKI =34hr ; PAUL =36 ; SV=34
1302-270	3 PF Coils - FDR	0	R	05FEB08	24MAR08	36	0.00	0.00	
1302-275	Resolve FDR Chits	10	06FEB08	19FEB08	24APR08	154	0.00	14,860.80	CHRZANOWSKI =40hr ; SV=40



# Procurement Plan / Issues

NCSX

---

- Expedite delivery by pre-ordering copper conductor and supplying to vendor / vendors
- Include three coils in one procurement but allow vendors to bid on subsets (Likely that more vendors will bid on smaller PF4 Coil)
- A preliminary information package has been posted to solicit bids on the Federal Business Opportunities web site and the PPPL web site
- A list of potential bidders is compiled
- Everson-Tesla Inc. has indicated strong interest in building PF coils
- Schedule and Cost estimates are based on budgetary information received from Everson as well as PPPL derived estimates
- Critical need dates driven by the installation of the lower PF5 and PF6 Coils. Vendors will be asked to stage deliveries so that these coils are received first.
- Begin early start of procurement by forming SPEB prior to FDR

# Near Term Procurement Schedule

NCSX

Task #	Description	Duration	Planned Start	Planned Finish	Actual Start	Actual Finish
1.	Issue Sources Sought FedBizOpps Notice		12/11/07	12/11/07		12/11/07
2.	Receive Statements of Interest		12/11/07	1/04/08 <sup>1</sup>		
3.	Requisition issued		1/09/08	1/09/08		
4.	SPEB Appointed		1/11/08	1/11/08		
5.	Source Selection Plan drafted	3 days	1/15/08	1/17/08		
6.	PF Coil FDR			2/05/08		
7.	Specification/Drawings Finalized	14 days	2/06/08	2/19/08		
8.	RFP issued	2 days	2/20/08	2/21/08		
9.	Pre-Proposal Conference			2/28/08		
10.	Proposals due	32 days	2/22/08	3/24/08		
11.	Proposal Evaluation Completed	14 days	3/25/08	4/08/08		
12.	SPEB Recommendation Completed	3 days	4/09/08	4/11/08		
13.	SSO Decision	5 days	4/12/08	4/16/08		
14.	Subcontract Negotiation	7 days	4/17/08	4/23/08		
15.	Subcontract Awarded	2 days	4/24/08	4/25/08		
16.	Delivery of Lower PF Coil #4, #5 and #6	222 days	4/25/08	12/02/08		
17.	Delivery of Upper PF Coil #5, #5, and #6	393 days	4/25/08	5/22/09		

# PF Coil Fabrication Schedule

1302-275	Resolve FDR Chits	10	06FEB08	19FEB08	21APR08	154	0.00	14,860.80	CHRZANOWSKI =40hr ; SV=40
<b>Job: 1352 - PF Coil Procurement-KALISH</b>									
<b>PF Coil Fabrication</b>									
141-035	Bid & Award PF Coil Fabrication	58	06FEB08	25APR08	27MAY08	36	0.00	35,811.60	CHRZANOWSKI=80hr ; 35=055k ; SV=80
141-036	2 PF Coils Awarded	0		20APR08	27MAY08	36	0.00	0.00	
141-037	Bid & Award Conductor	25	28MAR08	01MAY08	27MAY08	102	0.00	8,916.48	CHRZANOWSKI =48hr ;
141-038	3 PF Conductor Awarded	0		01MAY08*	27MAY08*	102	0.00	0.00	
141-038.1	PF Conductor Delivery	65	02MAY08	04AUG08	27AUG08	102	0.00	149,635.20	1=114.45k ;
141-039	Bid & Award Materials	25	27JUN08	01AUG08	01AUG08	58	0.00	8,916.48	CHRZANOWSKI =48hr ;
141-040	PF Materials Awarded	0		01AUG08*	01AUG08*	58	0.00	0.00	

Activity ID	MLE	Activity Description	Duration (work days)	Shifts	Forecast Start	Forecast Finish	Baseline Finish	Total Float	%	Earned value cost (BCWP)	Budget	FY08	FY09	FY10	FY11
1352-100		Materials Delivery PF 4,5,6	45		04AUG08	06OCT08	06OCT08	58		0.00	178,529.66				
1352-121		Design/Fab Tooling for PF 5	80		28APR08	19AUG08	18SEP08	36		0.00	280,747.50				
1352-122		Design/Fab Tooling for PF 6	80		28APR08	19AUG08	17NOV08	81		0.00	328,102.50				
1352-120		Tooling for PF 4	55		25JUL08*	10OCT08	10OCT08	54		0.00	74,072.29				
1352-150		Fabricate/Dlvr PF 4 lower	35		13OCT08	02DEC08	02DEC08	54		0.00	21,125.10				
1352-151		Fabricate/Dlvr PF 4 upper	45		03DEC08	12FEB09	12FEB09	405		0.00	21,125.10				
1352-165		Fabricate/Dlvr PF 5 Lower	45		20AUG08	22OCT08	20NOV08	36		0.00	72,965.95				
1352-145		Fabricate/Dlvr PF 6 Lower	45		23OCT08	06JAN09	04FEB09	36		0.00	86,654.95				
1352-166		Fabricate/Dlvr PF 5 Upper	35		07JAN09	24FEB09	25MAR09	362		0.00	74,148.05				
1352-146		Fabricate/Dlvr PF 6 Upper	35		25FEB09	14APR09	13MAY09	362		0.00	86,654.95				
141-031		Title III engr WBS 132	241		02MAY08	21APR09	14MAY09	863	LOE	0.00	148,047.04				
141-900		PF4 Lower Inspection & Test	5		03DEC08	09DEC08	09DEC08	54		0.00	3,561.30				
141-900A		PF4 Upper Inspection & Test	5		13FEB09	19FEB09	19FEB09	405		0.00	3,561.30				
141-901		PF5 Lower Inspection & Test	5		23OCT08	29OCT08	01DEC08	81		0.00	3,561.30				
141-902		PF6 Lower Inspection & Test	5		07JAN09	13JAN09	11FEB09	36		0.00	3,561.30				
141-905		PF5 Upper Inspection & Test	5		25FEB09	03MAR09	01APR09	397		0.00	3,561.30				
141-906		PF6 Upper Inspection & Test	5		15APR09	21APR09	20MAY09	362		0.00	3,561.30				
141-903		Refurbish PF 1a	20		18FEB10*	17MAR10	17MAR10	101		0.00	6,820.80				
141-904		Assemble PF1a and CS structure	30		18MAR10	28APR10	28APR10	101		0.00	21,550.00				

# PF Coil Baseline Cost Estimate

NCSX

---

- **Current Baseline Cost Estimate Remains Unchanged**
- **Estimate driven by vendor budgetary estimates**
- **Large PF5 and PF6 Coils driven by fixture cost**
- **Alternate cost saving fixtures identified but initial more expensive approach (+\$300K) used to generate baseline estimate**
- **Baseline materials estimate generated based on insulation and copper conductor cost as of May 07**
- **Copper prices dropped 15% (about \$17K) since estimate**
- **Alternative in house fabrication estimate did not compare favorably to vendor estimates**
- **Baseline estimate includes \$\$\$ to buy enough copper for one spare coil of any type to reduce risk**

# Issues Leading To FDR

NCSX

---

- **Resolve Support Structure Differential Temperature Operational Restrictions**
- **Initiate Conductor Procurement**
- **Finalize Details of Lead Area**
- **Finalize / confirm lead area field perturbation analysis**
- **Check Calculations**
- **Complete Detailed Drawings**
- **Complete Specifications**

# Charge to Committee

NCSX

---

- Verify that all requirements are being addressed. Identify requirements or design conflicts and potential “show stoppers”.
- Review the results of analyses, calculations, and tests conducted to obtain additional information for the design
- Review the ability to implement the proposed design taking into consideration capabilities, tolerances, costs, quality, reliability, and ES&H security.
- Review procurement issues, e.g. build vs. buy.
- Review test requirements and plans.
- Review updated design and development plans and schedules.
- Assure the appropriate incorporation of recommendations from previous design reviews.
- Review manufacturability.