



# NCSX Poloidal Field Coil Final Design Review

NCSX



James H. Chrzanowski

Michael Kalish

Bruce Paul

Joseph Rushinski

Fred Dahlgren

Len Myatt

# Outline

NCSX

---

- *Charge for Review Committee*
- *Requirements*
- *Analysis*
- *Design*
  - *Documentation and Drawings*
- *Chits from Previous Reviews*
- *Procurement Plan, Cost and Schedule*

# Charge to Review Committee

NCSX

---

- **Are the requirements defined? What is the proposed design?**
- **Is the analysis consistent with the proposed design?**
- **Are fabrication documents (drawings, specifications) complete?**
- **Are there satisfactory fabrication plans?**
- **Have prior design review chits been addressed?**
- **Have all technical, cost/schedule, and safety risks been addressed?**

# Requirements

NCSX

- The PF coils will be designed to meet the requirements of all the reference scenarios. [Ref. GRD Section 3.2.1.5.3.3.2]
  - 1.7 T Ohmic Scenario
  - 1.7 T High Beta Scenario
  - 2 T High Beta Scenario
  - 1.2 T Long Pulse
  - 320 kA Ohmic Scenario
- Electrical [Refer. GRD Appendix A.2.3.4]
  - Voltage standoff to resist maximum operating voltage of 2 KV for PF4 and PF6 in series
  - Voltage standoff to resist maximum operating voltage of 2KV for PF5 upper and lower [capability to be powered separately]
  - Define Maintenance Test, Manufacturing Test, and Design Standoff values for the PF coils

# Requirements

NCSX

---


## Tolerance / Location

- Global requirement is that toroidal flux in island regions shall not exceed 10%
- In plane installed perturbations less than +/- 3mm
- Out of plane installed perturbations less than +/- 3mm
- Leads and Transitions must have a less than 1% effect on toroidal flux in island regions
- **Cooling**
  - Pre-Pulse Temp of 80 K
  - Pulse repetition rate recovery shall not exceed 15 minutes
- **Design Life**
  - 13,000 cycles per year
  - 130,000 cycles per lifetime

# PF Coil Locations

NCSX


Day #1-  
Use existing  
NSTX PF1A  
coils



# PF Coil Construction

NCSX

- Conventional design and construction
- Round Geometry
- Extruded copper conductor
- Induction braze joints
- Glass and Kapton turn insulation
- Glass groundwall insulation
- VPI coil using CTD-101 K epoxy system [used on Modular and TF coils]












# Conductor for PF Coils

NCSX



- A single extruded copper conductor size will be used for all three types of PF coils.

- Conductor specification & SOW has been generated and approved

- NCSX-CSPEC-132-04

- NCSX-SOW-132-01

- Conductor Details:

- 0.787 x 0.787 inch


- 0.354 inch dia. Hole

- Silver-bearing OFC grade CDA 104, 105 or 107

- Requisition no. 405978 has been submitted and bids are due this work

# PF Lead Blocks

NCSX



- Leads locked together using G11 Blocks and pins
- Forces on leads very low on the order of 10 lbs excluding exterior fields
- Fiberglass overwrap applied over G-11 blocks

# PF Coil T/T Insulation Scheme

NCSX


- $\frac{1}{2}$  Lap Layer of Kapton to provide primary dielectric strength
- Releasing Kapton layer resolves thermal stress issue.
- Analysis verifies that coil stiffness is adequate after releasing insulation from conductors
- Prototype testing proved out insulation winding pack approach



# PF Turn to Turn Insulation

NCSX

PF Turn Insulation		Thickness	Dielectric Strength
1/2 Lap Layer of Kapton	Kapton	0.002	12.20
	Adhesive	0.0015	0.00
	Kapton	0.002	0.00
	Adhesive	0.0015	0.00
1/2 Lap Layer Dry Glass	Glass	0.007	2.10
	Glass	0.007	2.10
1/2 Lap Layer Dry Glass	Glass	0.007	2.10
	Glass	0.007	2.10
1/2 Lap Layer Dry Glass	Glass	0.007	2.10
	Glass	0.007	2.10
		<b>0.049 Inches</b>	<b>24.80 KV</b>



CTD Test Data: Glass/Epoxy  
 S-2 fiberglass and CTD-101K resin system  
 @76 degrees K~ 76.3 KV/mm = 3 KV/mil ~ **assume 300 V/ mil**

DuPont Data: Kapton HN  
 2 mil thick insulation:  
 6100 volts per mil = 12,200 volts

- Turn Insulation is comprised of [1] half-lapped layer of Kapton Tape [0.0035 in.] plus [3] half-lapped layers of S-2 fiberglass tape [0.007 in.]
- Turn to turn dielectric strength ~  $24.8 \times 2 = 49.6 \text{ KV}$
- Kapton allows for decoupling of insulation from conductor during cool down.

# PF Groundwall Insulation

NCSX

PF- Ground Wrap Insulation		Thickness	Dielectric Strength	
1/2 Lap Layer Dry Glass	Glass	0.165	49.50	
[11] layers x 0.015 in.	Glass	0.165	49.50	
1/2 Lap Layer Dry Glass	Glass	0.024	7.20	
[2] layers x 0.012 in.	Glass	0.024	7.20	
		<b>0.378</b>	<b>Inches</b>	<b>113.40 KV</b>

- Ground wall has been increased to 3/8 inch thick of S-2 glass and epoxy [CTD-101K]
- Provides electrical standoff, mechanical structure and exterior toughness
- Groundwall dielectric strength= 113.4 + 24.8 [turn] = **138.2 KV**



CTD Test Data: Glass/Epoxy

S-2 fiberglass and CTD-101K resin system

@76 degrees K~ 76.3 KV/mm = 3 KV/mil ~ **assume 10% of test value = 300 V/ mil**

# PF Leads Tracking Distance

NCSX





- Tracking distance “Rule of Thumb”: 1 inch for 20 kV [based upon testing]
- The leads for the PF-4 and PF-5 coils provides adequate space for G-11 shields and distance
- A minimum of 60 KV tracking distance can be achieved
- PF-6 will requires additional care in achieving our goal



# PF Leads and Tracking Distance

NCSX



- Due to the close proximity of the cooling fittings on PF-6, an additional Kapton cuff will be required after the VPI operations
- I recommend that this work be completed by PPPL after the coils have been delivered

# Turn To Turn Voltage Standoff Requirement

NCSX

## NCSX Coil Voltage Standoff Requirements Turn to Turn

		PF4 Upper & Lower	PF5 Upper	PF5 Lower	PF6 Upper & Lower
Operating Voltage (KV) across coil		2.00	2.00	2.00	2.00
Turn to Turn (KV) per coil		0.25	1	1	1
Maintenance Field Test Voltage (KV)	(Operating Voltage x 2) + 1	1.50	3.00	3.00	3.00
Manufacturing Test Voltage (KV)	Maintenance Test Voltage x 1.5	2.25	4.50	4.50	4.50
Design Voltage Standoff (KV)	Manufacturing Test Voltage x 1.5	<b>3.38</b>	<b>6.75</b>	<b>6.75</b>	<b>6.75</b>
Coil Turn to Turn Break Down		<b>49.60</b>	<b>49.60</b>	<b>49.60</b>	<b>49.60</b>
Safety Factor		<b>14.7</b>	<b>7.3</b>	<b>7.3</b>	<b>7.3</b>

- Substantial Margins in Turn to Turn Dielectric Standoff
- Design for 49 KV
- Coils nominally see 1 KV or less Turn to Turn
- Upper and Lower PF5 not in series [independently powered]

# Ground Plane Voltage Standoff Requirement

NCSX

## NCSX Coil Voltage Standoff Requirements to Ground

		PF4 Upper & Lower	PF5 Upper	PF5 Lower	PF6 Upper & Lower
<b>Operating Voltage (KV)</b>		2.00	2.00	2.00	2.00
<b>Maintenance Field Test Voltage (KV)</b>	(Operating Voltage x 2) + 1	5.00	5.00	5.00	5.00
<b>Manufacturing Test Voltage (KV)</b>	Maintenance Test Voltage x 1.5	7.50	7.50	7.50	7.50
<b>Design Voltage Standoff (KV)</b>	Manufacturing Test Voltage x 1.5	11.25	11.25	11.25	11.25
<b>Groundwrap Breakdown (KV)</b>	Groundwrap plus Turn to turn	138.20	138.20	138.20	138.20
<b>Safety Factor</b>		12.3	12.3	12.3	12.3

- Voltage standoff to resist maximum operating voltage of 2 KV
- Maintenance Test, Manufacturing Test, and Design Standoff formulas defined
- Design Voltage Standoff to ground is 138 KV for all three coils
- Ground Wrap dielectric standoff requirement meets system requirement


# Manufacturability - Manufacturing Tolerances

NCSX

- Requirement = In plane and out of plane installed perturbations shall be less than +/- 3 mm
- Coil specification will require +/- 1.5 mm using half of the allowable installed tolerance budget
- D Shaped NCSX TF Coils have been manufactured to about a +/- 1.5mm tolerance in their free state but a guarantee of that over the larger diameters for the PF Coils is not guaranteed
- Coil as it is removed from the VPI mold will be within +/- 1mm but coil is likely to distort in it's free state
- Support structure must be capable of re-shaping coil as required
- Coils can be positioned during installation to average out of tolerance conditions

# Manufacturability- TF Brazed Joint

NCSX



- **Example of a Typical Brazed Joint**

- OFHC copper sleeve is used with “Sil-Fos” Wafer and 1.5 mm diameter ring to ensure full coverage and no voids
- Induction brazing will be required for quality repeatability of braze joints. Potential vendors will have to possess, rent or procure unit for the PF coils

# Sensor Loop Placement

NCSX

---

- Co-wound diagnostic sensor Loops will be applied to ID of each PF coil
- These will be provided by PPPL to the coil vendor along with details on the proper installation.
- The diagnostic loops will be similar to the ones used on the TF coils
- Applied under last layer of ground wrap insulation
- The diagnostic leads will be twisted and brought out near the coil leads
- PPPL will provide a plastic box that will be attached to the coil for protecting the diagnostic leads

# Thermal / Hydraulic Analysis Requirements

NCSX

- Peak temperature and recovery time calculated for maximum required pulse (highest  $I^2t$  Operating Scenario) for each coil per the GRD
- Pulse Repetition not to exceed 15 minutes

	<b>PF 4</b>	<b>PF5</b>	<b>PF6</b>
<b>Operating Scenario</b>	320 kA Ohmic	1.7T High Beta	1.7T Ohmic
<b>Equivalent Square Wave</b>	.65 Seconds	.54 Seconds	.73 Seconds
<b>Max Current</b>	15155 Amps	7728 Amps	8195 Amps

# Thermal / Hydraulic Analysis Results

NCSX

---

- The pressure differential requirement is 60 psi for PF4 (same as the TF Coils).
- PF4 Peak temperature rise is 5 deg C
- PF4 base temperature increases by 3 deg C and then cycles 2 deg per each 15 minute pulse.
- PF5 and PF6 experience total temperature excursions of less than 2 deg C
- LN2 system Flow requirement is between 1 and 1.2 GPM per coil
- Total flow requirement for all six coils is less than 7 GPM



# Stress Analysis Inputs

NCSX

- Time points analyzed for all scenarios
- Highest Loads not necessarily at maximum currents
- Coils analyzed with fixed and flexible supports
- Coils analyzed with and without thermal stress for worst case (highest force) operating conditions

Table 2.0-1 Magnetic Forces from Max Current Time Points

Time Point	PF4U	PF5U	PF6U
	[kN] Vertical/Radial	[kN] Vertical/Radial	[kN] Vertical/Radial
1.7 T Ohmic, t=0.0 s (PF6 I <sub>min</sub> )	<b>-222/+725</b>	<b>+85/+22</b>	<b>-82/+53</b>
2.0 T High-β, t=0.197 s (PF6 I <sub>max</sub> )	-87/+820	-11/+46	+10/+36
320 kA Ohmic, t=0.206 s (PF4 I <sub>min</sub> )	<b>-201/+1984</b>	<b>-10/+82</b>	<b>+18/+19</b>
1.7 T High-β, t=0.0 s (PF5 I <sub>max</sub> )	-46/+118	+68/+23	-72/+51
Gravity (from 3D ANSYS model)	-9.8/0	-14/0	-9.6/0

# Stress Analysis Thermal vs EM Hoop Deflections

NCSX

- Initial calculation demonstrates thermal deflections due to cool down predominate
- EM Hoop stress and deflection is insignificant
- Analysis indicates overall stresses are low if cool down is homogeneous




Table 2.0-2 Nominal Coil Hoop Stress and Radial Deflection

PF	Radial Force, $F_r$ [kN]	Coil Dimensions [m]			Ave. Hoop Stress, $\sigma_h$ $F_r/(2\pi r dr dz)$ [MPa]	Ave. Hoop Modulus <sup>1</sup> E [GPa]	Deflection [mm]	
		r	dr	dz			Magnetic $(\sigma_h/E)r$	Thermal $(\alpha\Delta T)r$
4	1984	0.522	0.1852	0.2473	7	93	0.04	1.5
5	82	2.223	0.0922	0.1574	1		0.02	6.2
6	53	2.720	0.0457	0.1798	1		0.03	7.6

# Stress Analysis – Copper Conductor

NCSX


- Allowable copper stress  $S_m$  is 110 MPa
- With coils and structure at the same temperature there remains a factor of safety of at least two
- Present structure design utilizes a clamped configuration

Run	PF	Radial Constraint	Temp Coil/Structure [K]	LC	Conductor Stress Intensity [MPa]
10	4	free	85/85	0	46.6
15		free	300/300	2	19.2
12		free	85/85	2	49.1
13		clamped	85/85	2	48.0
114		clamped	85/300	0	731
16	5	free	85/85	1	49.2
14		free	85/85	2	46.1
19		free	85/85	0	46.1
111		clamped	85/85	0	53.1
113		clamped	85/300	0	588
18	6	free	85/85	0	48.1
17		free	85/85	1	51.0
110		clamped	85/85	0	54.6
112		clamped	85/300	0	744

# Stress Analysis - Copper / Structure Results were checked

NCSX

- Analysis performed for Structure confirms low stresses [19 MPa] when coil and structure are at same temperatures
- This analysis was performed by Fred Dahlgren who verified the calculations made by Len Myatt
- However, if the coils temperature between the coils and structure are not matched, unacceptable high stresses result.
- PF6 Cu Stresses approach 620 MPa midway between coil supports with coil at 85K and coil supports at 300K
- PF4 and PF5 stresses are as high
- Operational control of the cool down process will be critical



# Stress Analysis Insulation - In Plane & Compression

NCSX


- Stress allowable in plane limited to 165 MPA
- Stress allowable compression limited to 460 MPa
- Insulation Stress “In-Plane” and “Compression” has large margin
- Component of stress due to EM loads is very small

Run	PF	Radial Constraint	Temp Coil/Structure [K]	LC	In-Plane Compression/Tension [MPa]	Flat-Wise Compression [MPa]
10	4	free	85/85	0	-42.9/+9.6	-6.3
15		free	300/300	2	-0.6/+3.4	-3.0
12		free	85/85	2	-42.5/+10.1	-8.3
13		clamped	85/85	2	-41.4/+10.8	-8.3
114		clamped	85/300	0	-93.9/+81.3	-177
16	5	free	85/85	1	-40.9/+10.6	-7.4
14		free	85/85	2	-41.1/+10.4	-7.1
19		free	85/85	0	-40.7/+10.3	-7.1
111		clamped	85/85	0	-39.0/+12.9	-7.2
113		clamped	85/300	0	-49.5/+103	-81.8
18	6	free	85/85	0	-39.6/+10.2	-6.4
17		free	85/85	1	-40.7/+10.5	-6.6
110		clamped	85/85	0	-36.6/+13.0	-7.5
112		clamped	85/300	0	-110/+140	-99.5

# Stress Analysis Insulation Tensile

NCSX


- EM loads contribute insignificantly to the tensile insulation stress
- Analysis of local tensile loads indicates failure of the bond to the cooper conductor
- Testing pursued to determine if higher allowable tensile value could be used
- Testing indicates that tensile allowable is between “0” and 4.4 MPa



# Projected Fatigue Life for Conductor

NCSX

- Allowable number of cycles (N) based on 20 MPa alternating stress is greater than 100,000,000 (~infinite)
- Actual number of required cycles is 130,000



Fatigue Curve

# Analysis and Testing Summary

NCSX

---

- Analysis completed for operating scenarios / requirements as specified in the GRD
- Coils meet 15 minute rep rate with a maximum 5 deg C rise
- Conductor meets stress requirements with margin
- Insulation satisfies all relevant stress requirements with margin for in plane and compressive stress
- Cryogenic fatigue tests verify validity of Kapton to conductor insulation scheme at required fatigue life to satisfy tensile stress requirement
- Testing verifies analysis assumptions for composite beam properties
- Testing verifies dielectric standoff for turn to turn and turn to ground requirements



# Requirements Addressed

NCSX

---

- The PF coils are designed to meet the requirements of all the reference scenarios. [Ref. GRD Section 3.2.1.5.3.3.2]
  - *Stress analysis acceptable for all operating scenarios*
- **Electrical**
  - *Design meets electrical voltage standoff requirements [verified by testing]*
- **Tolerance / Location**
  - *Procurement specification will address tolerances*
  - *May require structure to compensate*
- **Cooling**
  - *Analysis confirms acceptable temperature rise and rep rate*
- **Design Life**
  - *Testing and analysis confirms fatigue life*

# PDR Chit Disposition- sheet 1

NCSX

Design Review/QA Audit [Cog Engr./RLM/Chair]	Review Date	#	Chit/Audit Finding [Originator]	Review Board Recommend.	Project Disposition
Kalish/Neumeyer/ Heitzenroeder PF Coil PDR	12/14/07	1	Verify configuration preserves stellarator symmetry i.e. bottom coils are installed rotated about machine "X" exit 180° [Brooks]	Concur	Coils are identical. Positioning of the coils in proper configuration for stellarator symmetry will have to be identified on final assembly drawings
Kalish/Neumeyer/ Heitzenroeder PF Coil PDR	12/14/07	2	Calculations establishing the voltage and number of turns and current requirements have to be referenced [Ramakrishnan]	Concur	All voltage and coil turns, current are based on the GRD
Kalish/Neumeyer/ Heitzenroeder PF Coil PDR	12/14/07	3	Consider using a ground plane [Neumeyer]	Concur	Ground planes are usually used for systems >5 Kv Availability of cryogenic compatible ground plane is not known
Kalish/Neumeyer/ Heitzenroeder PF Coil PDR	12/14/07	4	Sensor loop may have noise problem unless there is a shield via ground plane in coil or around sensor loops. Proper designer would place sensor outside of ground plane [Neumeyer]		Similar arrangement was used for both modular and TF coils Diagnostic group should determine whether this will be a problem in any of the coil systems
Kalish/Neumeyer/ Heitzenroeder PF Coil PDR	12/14/07	5	Check calculations of turn-to-turn voltage. [Neumeyer]	Concur	Turn to turn voltages were re-examined by J. Chrzanowski & presented in this FDR
Kalish/Neumeyer/ Heitzenroeder PF Coil PDR	12/14/07	6	Max turn to turn voltage to the specifiers. [Ramakrishnan]	Concur [See chit 5]	See chit #5

# PDR Chit Disposition- sheet 2

NCSX

Design Review/QA Audit [Cog Engr./RLM/Chair]	Review Date	#	Chit/Audit Finding [Originator]	Review Board Recomm	Project Disposition
Kalish/Neumeyer/ Heitzenroeder PF Coil PDR	12/14/07	7	Need to establish minimum lead to lead and lead to ground creeping distances for lead's to ensure safety margin on leads. [Neumeyer]	Concur	Concur- Presented in FDR
Kalish/Neumeyer/ Heitzenroeder PF Coil PDR	12/14/07	8	Need to plan to measure coil copper temperature to prevent flow of LN2 into warm coil. T/C's in copper not recommended. Consider fiber optic probe or resistance measured scheme [Neumeyer]	Concur	Thermocouples will be included on supply and return points later by I&C group No TC's are being installed on coil as part of PF fabrication
Kalish/Neumeyer/ Heitzenroeder PF Coil PDR	12/14/07	9	Who is responsible for coil protection due to thermal shock? Will this be covered as part of WBS 5 (I&L) with interlocks to the cryogenic system? [Strykowski]	Other [See Chit 8]	See chit #8
Kalish/Neumeyer/ Heitzenroeder PF Coil PDR	12/14/07	10	The number of thermal cycles consideration for the design to be documented [Ramakrishnan]	Concur [If not already given in GRD]	Number of thermal cycles does not effect design of PF coils- No stress issues
Kalish/Neumeyer/ Heitzenroeder PF Coil PDR	12/14/07	11	The time at test voltage should be 1 min to allow for charging current to the level off and not influence the true leakage current. [Meighan]	Concur	This will be specified in coil specification

# PDR Chit Disposition- sheet 3

NCSX

Design Review/QA Audit [Cog Engr./RLM/Chair]	Review Date	#	Chit/Audit Finding [Originator]	Review Board Recomm	Project Disposition
Kalish/Neumeyer/ Heitzenroeder PF Coil PDR	12/14/07	12	Coil shape should be maintained with bracing from time of VPI completed until coils are installed in machine this will minimize reshaping (PF-5 and PF-6 only) [Chrzanowski]	Concur	SOW will include requirement for shipping structure to maintain coil shape
Kalish/Neumeyer/ Heitzenroeder PF Coil PDR	12/14/07	13	Special stripping instructions are required. [Ramakrishnan]	Other [See Chit 12]	See chit #12

# Procurement Plan / Issues

NCSX

- Expedite delivery by pre-ordering copper conductor and supplying to vendor / vendors [**Requisition has been submitted award by 2/25/08**]
- RFQ will include three options:
  - PF-4, PF-5 and PF-6 as one procurement
  - PF-5 and PF-6 together
  - PF-4 separately
- A list of potential bidders has been compiled
- Schedule and Cost estimates are based on budgetary information received from Everson as well as PPPL derived estimates
- Critical need dates driven by the installation of the lower PF5 and PF6 Coils. Vendors will be asked to stage deliveries so that these coils are received first. [**Lower PF-5 & 6 first**]
- Have already begun early start of procurement. [**SPEB has already been formed and have met**]

# PF Coil Procurement Schedule

NCSX


Task #	Description	Responsible	Duration	Planned Start	Planned Finish	Actual Start	Actual Finish
1.	Issue Sources Sought FedBizOpps Notice	LLS		12/11/07	12/11/07		12/11/07
2.	Receive Statements of Interest	LLS		12/11/07	1/04/08		
3.	Requisition issued	JHC		1/09/08	1/09/08		
4a.	SPEB Members Nominated	JHC		1/4/08	1/04/08		1/03/08
4.	SPEB Appointed	RJH		1/11/08	1/11/08		1/03/08
5.	Source Selection Plan drafted	LLS	3 days	1/15/08	1/17/08		1/18/08
6.	PF Coil FDR	JHC			2/20/08		FDR
7.	Specification/Drawings Finalized	JHC	14 days	2/12/08	2/25/08		
8.	RFP issued	LLS	3 days	2/25/08	2/28/08		
9.	PPPL Provided Material On Order	JHC			2/25/08		
10.	Pre-Proposal Conference	LLS/JHC			3/07/08		
11.	Proposals due	LLS	28 days	2/29/08	3/27/08		
12.	Proposal Evaluation Completed	SPEB	14 days	3/28/08	4/10/08		
13.	SPEB Recommendation Completed	SPEB	5 days	4/11/08	4/15/08		
14.	SSO Decision	RJH	3 days	4/16/08	4/18/08		
15.	Subcontract Negotiation – DOE Approval <sup>1</sup>	LLS	14 days	4/19/08	5/02/08		
16.	Subcontract Awarded	LLS	4 days	5/03/08	5/06/08		AWARD
17.	Subcontractor receive PPPL Material	JHC		6/02/08	6/02/08		
18.	Delivery of Lower PF Coils #5 and #6	Contractor	293 days	5/06/08	2/23/09		
19.	Delivery of Lower PF4 and Upper #4,5,6	Contractor	512 days	5/06/08	9/30/09		

<sup>1</sup> DOE PSO approval of Subcontract required if the price exceeds \$1 million.

# PF Coil Fabrication/Delivery Schedule

NCSX

Activity ID	MILE	Activity Description	Duration (work days)	Forecast Start	Forecast Finish	Baseline Finish	Total Float	%	Earned value cost (BCWP)	Budget	Target 2 Budgeted Cost	FY07	FY08	FY09
cc 9450 - NCSX Fabrication (MIE)														
13 - Conventional Coils														
Job: 1352 - PF Coil Procurement-CHRZANOWSKI														
PF Coil Fabrication														
141-035		Bid & Award PF Coil Fabrication	58	12FEB08	01MAY08	27MAY08	32		0.00	35,811.60	35,811.60			
141-036	2	PF Coils Awarded	0		01MAY08	27MAY08	32		0.00	0.00	0.00			
141-037		Bid & Award Conductor	25	28MAR08	01MAY08	27MAY08	102		0.00	8,916.48	8,916.48			
141-038	3	PF Conductor Awarded	0		01MAY08*	27MAY08*	102		0.00	0.00	0.00			
141-038.1		PF Conductor Delivery	65	02MAY08	04AUG08	27AUG08	102		0.00	149,635.20	149,635.20			
141-039		Bid & Award Materials	25	27JUN08	01AUG08	01AUG08	58		0.00	8,916.48	8,916.48			
141-040		PF Materials Awarded	0		01AUG08*	01AUG08*	58		0.00	0.00	0.00			
1352-100		Materials Delivery PF 4,5,6	45	04AUG08	06OCT08	06OCT08	58		0.00	178,529.66	178,529.66			
1352-121		Design/Fab Tooling for PF 5	80	02MAY08	25AUG08	18SEP08	32		0.00	280,747.50	280,747.50			
1352-122		Design/Fab Tooling for PF 6	80	02MAY08	25AUG08	17NOV08	77		0.00	328,102.50	328,102.50			
1352-120		Tooling for PF 4	55	25JUL08*	10OCT08	10OCT08	54		0.00	74,072.29	74,072.29			
1352-150		Fabricate/Dlvr PF 4 lower	35	13OCT08	02DEC08	02DEC08	54		0.00	21,125.10	21,125.10			
1352-151		Fabricate/Dlvr PF 4 upper	45	03DEC08	12FEB09	12FEB09	405		0.00	21,125.10	21,125.10			
1352-165		Fabricate/Dlvr PF 5 Lower	45	26AUG08	28OCT08	20NOV08	32		0.00	73,128.99	72,965.95			
1352-145		Fabricate/Dlvr PF 6 Lower	45	29OCT08	12JAN09	04FEB09	32		0.00	86,654.95	86,654.95			
1352-166		Fabricate/Dlvr PF 5 Upper	35	13JAN09	02MAR09	25MAR09	358		0.00	74,148.05	74,148.05			
1352-146		Fabricate/Dlvr PF 6 Upper	35	03MAR09	20APR09	13MAY09	358		0.00	86,654.95	86,654.95			
141-031		Title III engr WBS 132	241	02MAY08	21APR09	14MAY09	863	LOE	0.00	148,047.04	148,047.04			
141-900		PF4 Lower Inspection & Test	5	03DEC08	09DEC08	09DEC08	54		0.00	3,561.30	3,561.30			
141-900A		PF4 Upper Inspection & Test	5	13FEB09	19FEB09	19FEB09	405		0.00	3,561.30	3,561.30			
141-901		PF5 Lower Inspection & Test	5	29OCT08	04NOV08	01DEC08	77		0.00	3,561.30	3,561.30			
141-902		PF6 Lower Inspection & Test	5	13JAN09	19JAN09	11FEB09	32		0.00	3,561.30	3,561.30			
141-905		PF5 Upper Inspection & Test	5	03MAR09	09MAR09	01APR09	393		0.00	3,561.30	3,561.30			
141-906		PF6 Upper Inspection & Test	5	21APR09	27APR09	20MAY09	358		0.00	3,561.30	3,561.30			
141-903		Refurbish PF 1a	20	18FEB10*	17MAR10	17MAR10	101		0.00	6,820.80	6,820.80			
141-904		Assemble PF1a and CS structure	30	18MAR10	28APR10	28APR10	101		0.00	21,550.00	21,550.00			



# PF Coil Baseline Cost Estimate

NCSX

---

- **Current Baseline Cost Estimate Remains Unchanged**
- **Estimate driven by vendor budgetary estimates**
- **Baseline materials estimate generated based on insulation and copper conductor cost as of May 07**
- **Copper prices have risen and may cause slight increase in material estimate**
- **Alternative in house fabrication estimate did not compare favorably to vendor estimates**
- **Baseline estimate includes \$\$\$ to buy enough copper for one spare coil of any type to reduce risk**



# Summary

NCSX

---

- **Critical-** Operational Differential Temperature between Support Structure and coils needs to be addressed- Cool Down requirements
- Conductor requisition has been submitted to procurement
- Calculations have been checked by Fred Dahlgren
- Completed Detailed Drawings- being approved
- CSPEC nearly complete will be sent out for review this week
- SPEB has been established to begin the coil vendor selection
- SRD is also ready for review and approval [awaiting information from Mike Z.]