

National Compact Stellarator Experiment (NCSX)

Product Specification

Prototype Vacuum Vessel Segment

NCSX-CSPEC-121-01-00


14 November 2002

Prepared by:



P. Heitzenroeder, Technical Representative for WBS 12 Procurements

Concurrences:



P. Goranson, Vacuum Vessel (WBS 12) WBS Manager




B. Nelson, Project Engineer for Stellarator Core Systems (WBS 1)



F. Malinowski, PPPL Procurement QA Representative

Approved by:



W. Reiersen, Engineering Manager

Controlled Document

This is an uncontrolled copy of a controlled document once printed. Check the PPPL Procurement Web Site (<http://oorm-1.pppl.gov/public/procurement/>) prior to use to assure that this document is current.

Record of Revisions

Revision	Date	Description of Changes
Rev. 0	11/14/02	Initial release

Table of Contents

1	INTRODUCTION AND SCOPE.....	1
1.1	INTRODUCTION.....	1
1.2	SCOPE.....	3
2	APPLICABLE DOCUMENTS.....	3
3	REQUIREMENTS.....	4
3.1	ITEM DEFINITION.....	4
3.2	CHARACTERISTICS	6
3.2.1	Performance.....	6
3.2.1.1	Vacuum Performance.....	6
3.2.1.2	Surface Finish.....	6
3.2.1.2.1	Interior Surface Finish.....	6
3.2.1.2.2	External Surface Finish	6
3.2.1.3	Magnetic Permeability	6
3.3	DESIGN AND CONSTRUCTION	7
3.3.1	Fabrication Drawings.....	7
3.3.2	Materials, Processes, and Parts	8
3.3.2.1	Materials.....	8
3.3.2.1.1	Sheet, Strip, and Plate.....	8
3.3.2.1.2	Tubing and Pipe.....	8
3.3.2.1.3	Bar and Structural Shapes.....	8
3.3.2.1.4	Castings	8
3.3.2.1.5	Conflat Flanges.....	8
3.3.2.1.6	Weld Filler Metal	8
3.3.2.1.7	Bolts	8
3.3.2.1.8	Copper Seals.....	9
3.3.2.2	Welding.....	9
3.3.2.3	Cutting, Forming and Bending.....	9
3.3.2.4	Cleaning	9
4	QUALITY ASSURANCE PROVISIONS.....	9
4.1	GENERAL.....	9

- 4.1.1 Responsibility for Inspection10
- 4.2 QUALITY CONFORMANCE INSPECTIONS10
 - 4.2.1 Verification of Vacuum Performance10
 - 4.2.2 Verification of Surface Finish.....10
 - 4.2.3 Verification of Magnetic Permeability10
 - 4.2.4 Verification of Dimensions and Tolerances.....10
 - 4.2.5 Materials11
 - 4.2.6 Weld Inspection and Examination11
 - 4.2.7 Verification of Cutting, Forming, and Bending11
 - 4.2.8 Verification of Cleaning Requirements11
 - 4.2.9 Inspection for Internal Defects.....12
- 5 PREPARATION FOR DELIVERY 12**
 - 5.1 MARKING12
 - 5.2 CRATING12
 - 5.3 SHIPPING12

1 INTRODUCTION AND SCOPE

1.1 INTRODUCTION

Stellarators are a class of magnetic fusion confinement devices characterized by three dimensional magnetic fields and plasma shapes and are the best-developed class of magnetic fusion devices after the tokamak. The stellarator concept has greatly advanced since its invention by Dr. Lyman Spitzer, the founding director of the Princeton Plasma Physics Laboratory (PPPL), during the 1950's. A traditional stellarator uses only external magnetic fields to shape and confine the plasma. The differentiating feature of a compact stellarator is the use of plasma current in combination with external fields to accomplish shaping and confinement. This combination permits a more compact device. The NCSX project is managed by PPPL in partnership with the Oak Ridge National Laboratory. This Subcontract will be administered by PPPL. Operation of NCSX is scheduled to begin in July 2007.

The vacuum vessel is a key element in the stellarator core. The vacuum vessel is a contoured, three-period torus, which means that its geometry repeats every 120° toroidally. The geometry is also mirrored every 60° so that the first (0° to 60°) segment, if flipped over, is identical to the corresponding adjacent (60° to 120°) segment. The vacuum vessel assembly will be fabricated in three sub-assemblies that are bolted together and vacuum-sealed with double O-rings at flanges on the ends of each segment. Figure 1 shows the vessel segments during manufacture with the port reinforcements installed. The Subcontractor will need to supply temporary segment end covers so each segment can be individually tested.

With the exception of the large vertical ports and the neutral beam port located mid-segment, all port assembly extensions are required to be welded onto the three vessel sub-assemblies after installation of the modular coils and TF coils as part of the NCSX field period assembly operation. Assembly of the modular coils over a vacuum vessel sub-assembly is illustrated in Figure 2. Attachment of the port extensions is illustrated in Figure 3.

The vacuum vessel sub-assemblies will be supported from the modular coil shell structure via adjustable hangers. The interfacing fixed, structural brackets are part of the vacuum vessel assembly. ASME code stamping of the vacuum vessel sub-assemblies is NOT required.




Figure 1 - NCSX vacuum vessel sub-assemblies (partially fabricated)




Figure 2 - Modular coils being assembled over vacuum vessel sub-assembly




Figure 3 - Port extensions welded on after coils assembled

1.2 SCOPE

This specification establishes the manufacturing and acceptance requirements for the National Compact Stellarator Experiment (NCSX) Prototype Vacuum Vessel Segment (PVVS).

2 APPLICABLE DOCUMENTS

The versions of the United States Codes and Standards defined below are to be used in the performance of this work. Other equivalent foreign codes may be proposed:

- ASME B46.1-1995 Surface texture (Surface Roughness, Waviness, And Lay)
- ASME SFA specifications
- ASME SFA 5.14 Nickel and Nickel Alloy Bare Welding Rods Electrodes
- American Society of Mechanical Engineers (ASME), Boiler and Pressure Vessel Code, Sections V (Articles 6 and 9), VIII (Division 1), and IX, 1998 with 2000 Addendum.
- ASTM B 443-00 Standard Specification for Nickel-Chromium-Molybdenum-Columbium Alloy (UNS N06625) and Nickel-Chromium-Molybdenum-Silicon Alloy (UNS N06219)* Plate, Sheet, and Strip
- ASTM B 444-00 Standard Specification for Nickel-Chromium-Molybdenum-Columbium Alloys (UNS N06625) and Nickel-Chromium-Molybdenum-Silicon Alloy (UNS N06219)* Pipe and Tube
- ASTM B 705-00 Standard Specification for Nickel-Alloy (UNS N06625, N06219 and N08825) Welded Pipe
- ASTM B 446-00 Standard Specification for Nickel-Chromium-Molybdenum-Columbium Alloy (UNS N06625) and Nickel-Chromium-Molybdenum-Silicon Alloy (UNS N06219)* Rod and Bar
- ASTM A 240-02 Standard Specification for Chromium and Chromium-Nickel Stainless Steel Plate, Sheet, and Strip for Pressure Vessels and for General Applications
- ASTM A193/A193M-01b Standard Specification for Alloy-Steel and Stainless Steel Bolting Materials for High-Temperature Service
- ASTM A 800/A 800M-01 Practice for Steel Casting, Austenitic Alloy, Estimating Ferrite Content Thereof
- ASTM Spec. A 494-01 Standard Specification for Castings, Nickel and Nickel Alloy
- AWS D1.6: 1999 Structural Welding Code - Stainless Steel, (Paragraph 6.29.1)
- MSS SP-54-1999, Quality Standard for Steel Castings for Valves, Flanges and Fittings and Other Piping Components -- Radiographic Examination Method

- American Welding Society (AWS) QC1, Standard and Guide for Qualification and Certification of Welding Inspectors, 1996.
- American Society of Nondestructive Testing (ASNT) 2055, Recommended Practice SNT-TC-1A, 1996.

3 REQUIREMENTS

3.1 ITEM DEFINITION

The PVVS is a 20° segment of a full (120°) vacuum vessel sub-assembly. The PVVS extends from 10° to 30°, where 0° marks the center of a full sub-assembly. This section of a full sub-assembly features three ports. The PVVS will feature only one of the three ports. Finished port reinforcement and the associated port extension are to be included as a part of the PVVS. A view of the PVVS is provided in Figure 4. A port attachment concept is shown in Figure 5.




Figure 4 - View of PVVS




Figure 5 - Port attachment concept

3.2 CHARACTERISTICS

3.2.1 Performance

3.2.1.1 Vacuum Performance

The port extension included in the PVVS is to be leak checked. The port configuration during vacuum leak testing shall be:

- Prior to leak checking, the assembly shall be cleaned as defined in Sect. 3.3.2.4
- Vessel wall inside of reinforcement in place, as shown in Figure 4.
- Conflat flange, port cover, conflat seals and bolts in their operational configuration.

The port under test shall be evacuated using a turbo molecular pump to an internal pressure of $\leq 1 \times 10^{-7}$ torr. The total helium leak rate for the port extension shall be $\leq 1.7 \times 10^{-9}$ torr-l/s.

3.2.1.2 Surface Finish

3.2.1.2.1 Interior Surface Finish

Interior surface weld beads, scratches, tooling marks and other surface imperfections resulting from fabrication shall be ground to a 32 micro inch finish and shall be verified per ASME B46.1.

3.2.1.2.2 External Surface Finish

Mill finish on the exterior surfaces of the vessel is acceptable.

3.2.1.3 Magnetic Permeability

Overall relative magnetic permeability of all components fabricated of nickel chromium alloy shall not exceed 1.01.

Overall relative magnetic permeability of all components fabricated of 316 LN Stainless Steel shall not exceed 1.02.

Overall relative magnetic permeability in welds (and heat affected zones) joining 316 LN to nickel chromium shall not exceed 1.2.

3.3 DESIGN AND CONSTRUCTION

3.3.1 Fabrication Drawings

The Pro/Engineer CAD files listed in Table 1 shall be used to manufacture the PVVS. Tolerance requirements are provided in those drawings.

Table 1 - Fabrication drawings for the prototype vacuum vessel segment

The Pro/Engineer models and drawings of the PVVS are available through the PPPL anonymous FTP server. The following FTP commands can be used to access the files:

```
ftp> ftp.pppl.gov
User: anonymous          <- login as anonymous
Password:                <- enter your email address
ftp> cd pub/ncsx/manuf  <- lowercase
ftp> bin                 <- binary transfer mode
ftp> mget *              <- retrieve files
ftp> quit
```

The files may also be accessed through a web browser using the following URL address:

```
ftp://ftp.pppl.gov/pub/ncsx/manuf/
```

3.3.2 Materials, Processes, and Parts

3.3.2.1 Materials

3.3.2.1.1 Sheet, Strip, and Plate

All as-supplied sheet, strip, and plate shall be annealed Alloy (UNS N06625) and meet the requirements of ASTM B 443. If the Subcontractor proposes casting, samples of after-cast material will be required to be submitted for analysis and approval by the Laboratory with the Approval Data.

3.3.2.1.2 Tubing and Pipe

All tubing and pipe shall be seamless or welded Alloy (UNS N06625) and meet the requirements of ASTM B 444 or ASTM B 705.

3.3.2.1.3 Bar and Structural Shapes

All bar and structural shapes shall be annealed Alloy (UNS N06625) and meet the requirements of ASTM B 446.

3.3.2.1.4 Castings

If the Subcontractor proposes casting of the PVVS, the casting alloy shall be recommended such that properties are similar to Alloy (UNS N06625).

3.3.2.1.5 Conflat Flanges

The conflat flange shall be fabricated of 304 stainless steel and meet the requirements of ASTM A 240.

3.3.2.1.6 Weld Filler Metal

Weld filler metal shall meet the requirements of the applicable ASME SFA specifications. Welding of stainless steel conflat flanges to Alloy (UNS N06625) ports shall use ASME SFA 5.14 ERNiCr-3 or ERNiCrMo-3 filler metal.

3.3.2.1.7 Bolts

Conflat flange bolts shall be ASTM A 193, Grade B8; silver-plated, 12-point bolt kits provided with flanges from the flange manufacturer.

3.3.2.1.8 Copper Seals

Conflat flanges shall use standard copper seals provided from the flange manufacturer.

3.3.2.2 Welding

All welding shall be done in accordance with welding procedures that are written and qualified in accordance with the ASME Code, Section IX. Welds may be made by the GTAW or GMAW processes. Welds using SMAW process are not permitted.

3.3.2.3 Cutting, Forming and Bending

For the fabrication of the Vessel, all cutting, forming and bending shall be done in accordance with the ASME Boiler and Pressure Vessel Code, Section VIII, Division 1.

3.3.2.4 Cleaning

After completion of assembly and surface preparation, the PVVS interior shall be cleaned. All surfaces shall be degreased/cleaned using materials and procedures mutually agreed upon. As a minimum this procedure will include:

- Vapor degreasing to remove oils, greases, and die lubricant residues resulting from handling and fabrication of the Vessel.
- Solvent (e.g. ethanol) wipe down of the surfaces.
- Blow drying of surfaces with oil-free instrument air.
- Use of lint-free wipes.

4 QUALITY ASSURANCE PROVISIONS

4.1 GENERAL

Tests and inspections shall be conducted at the supplier's facility or otherwise suitable location. Actual data and accept/reject status for each inspection and test shall be documented. The reports shall contain sufficient information to accurately locate the area involved and to reproduce the inspection or test performed. This can be accomplished by reference to other Subcontractor-provided documents such as procedures and radiographs.

4.1.1 Responsibility for Inspection

The responsibility for performing all tests and verifications rests with the Subcontractor. PPPL reserves the right to witness or separately perform all tests specified or otherwise inspect any or all tests and inspections.

4.2 QUALITY CONFORMANCE INSPECTIONS

4.2.1 Verification of Vacuum Performance

Helium leak tests shall be performed to verify that the requirements stated in Sect. 3.2.1.1 are met.

4.2.2 Verification of Surface Finish

The interior surface finish shall be checked with a comparator to verify compliance with Section 3.2.1.2.1. The exterior surface finish shall be visually examined to verify compliance with Section 3.2.1.2.2.

4.2.3 Verification of Magnetic Permeability

Magnetic permeability shall be measured in accordance with the requirements of ASTM A 800, Supplementary Requirement S1 but the measurements shall be taken in relative permeability rather than ferrite content. All surfaces and features shall be checked with a calibrated Severn Permeability Indicator¹ for compliance with Section 3.2.1.6. The surfaces of the PVVS shell and port extension shall be checked and documented in a 6" x 6" grid. The welds at the conflat flanges and at the junction between the port extension, reinforcement, and vessel shell shall be checked every 1/2" (both inside and outside surfaces wherever possible).

4.2.4 Verification of Dimensions and Tolerances

With the PVVS unrestrained on a surface measuring table and the port extension supported to compensate for gravity load, all surfaces and features shall be dimensionally checked on a grid no coarser than 1-inch centers using instruments having resolution at least ten times the tolerance. These measurements shall be compared to the tolerances indicated on the applicable

¹ Available from Severn Engineering Co. Annapolis, Md.

drawings. Verification of dimension and tolerances shall be done both before and after attachment of the port extension.

4.2.5 Materials

Material certifications traceable to the materials used shall be provided as defined below. Subcontractor is to develop and utilize process controls to assure traceability of materials to their certifications.

- N06625: showing actual chemical and physical properties
- Bolts: Manufacturer's certification of grade
- Conflat flanges: Manufacturer's statement
- Filler metal: showing actual chemical properties

If cast material is used, Subcontractor is to provide verification of properties from test coupons. Properties must meet those specified in Section 3.3.2.1.4.

4.2.6 Weld Inspection and Examination

All welds are to be visually inspected using a written procedure prepared in accordance with Article 9 of Section V of the ASME Code. Welds designated with a "V" in the tail of the welds symbol shall also be visually examined with 8X magnification, in accordance with Article 6, Section V, of the ASME Code. The acceptance criteria for the visually inspected welds is given in AWS D1.6, Paragraph 6.29.1. All welds that do not meet the stated acceptance criteria shall be documented, repaired, and re-inspected.

Visual weld inspection shall be done by inspectors certified to perform visual inspection of welds in accordance with AWS QC1 or SNT-TC-1A, Level II or Level III.

Copies of welding heat treatment, NDE and special process procedures and qualification test records shall be available for review by PPPL. Welding procedures qualifications shall include evidence of compliance with special magnetic permeability criteria.

4.2.7 Verification of Cutting, Forming, and Bending

Copies of cutting, forming, and bending procedures shall be available for review by PPPL.

4.2.8 Verification of Cleaning Requirements

Visually inspect the PVVS and examine records for compliance with Section 3.3.2.4.

4.2.9 Inspection for Internal Defects

Castings shall be 100% examined for internal defects as defined in ASTM Spec. A 494 using radiographic inspection per Supplementary Requirement S2. Acceptance criteria for radiography shall be per MSS SP 54.

5 PREPARATION FOR DELIVERY

5.1 MARKING

The PVVS shall have its weight engraved or stamped at its outer horizontal centerline with characters 1/4" high.

5.2 CRATING

A crate shall protect the items from shock and weather conditions, including precipitation. The crate shall be built for moving on rollers, handling with slings from overhead cranes, and transport by forklifts.

5.3 SHIPPING

Subcontractor is responsible arranging shipment, and for the safe arrival of the vessel components at PPPL in Princeton, New Jersey, USA. Subcontractor's name, shipper, purchase order number, contents and gross weight shall be marked on the shipping container.